

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3225-1518:101

Page 1 of 1

CATEGORY: Fire Dampers

LISTEE: Prefco Products, Inc., 2823 Route 413, Buckingham, PA 18912
Contact: Richard McNutt (215) 340-1707

DESIGN: Models 5500 fire rated dampers. Models listed below:

<i>Models</i>	<i>Mounting Position</i>	<i>Rating Hour</i>	<i>Single Size, In.</i>		<i>Multiple Size, In.</i>	
			<i>W</i>	<i>H</i>	<i>W</i>	<i>H</i>
5500-E2A, -E2BC, -SF1.5, -E4A, -E4C, -SF2.5, -CO, -CR, -E6LPB, -E6BC, -SFLP	V	1-1/2	36	36	120	72
	H		36	36	114	60
5500-BF3, BFC3, -BFBC3, -BFCR3	V	3	30	30	60	60
5500-E4M, -E4ML, -E6LPC, -E6M, -E6ML	V	1-1/2	36	36	120	72
	H		36	36	114	60
5500-E2A, -E2BC, -SF1.5, -E4A, -E4C, -E4M, -E4ML, -SF2.5, -CO, -CR, -E6LPB, -E6LPC, -E6BC, -E6M, -E6ML, -SFLPB	V	1-1/2	60	48	120	72
	H		50	54	114	60

Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as fire rated dampers for use in heating, ventilating and air conditioning duct systems passing through fire resistive walls and partitions.

NOTE: Leakage rating not evaluated. Refer to CSFM Listing Category 3230 for leakage rated dampers.

10-20-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager